



NORTH STONINGTON

CONNECTICUT

LEGAL NOTICE

TOWN OF NORTH STONINGTON AND BOARD OF EDUCATION
REQUEST FOR PROPOSALS FOR ROOFTOP SOLAR PHOTOVOLTAIC SYSTEMS
ON MUNICIPAL AND SCHOOL FACILITIES

RFP AMENDMENT #3

Dated March 8, 2019

Response to Questions

Q1: Would you be able to provide the target usage offset for each of these locations? I realize that some of these buildings are either new or have been repurposed so their usage history from Eversource may not be accurate. If we could at least get an estimated target usage offset for each location it would really help me out with my designs.

A1: The Emergency Services building's annual usage is 69,500 kWh. The other buildings are either new construction, renovations, or being repurposed. As a result, the annual usage data is either not available or not reflective of the new use. Based on the facility use type, square footage, and renovation plans it is recommended to propose a system size that maximizes the available roof area and the small ZREC 100 kW-AC cap.

Q2: Do I need to use the exact layouts provided at the end of the RFP, or can I deviate slightly from those layouts?

A2: The layouts provided in the RFP are examples to demonstrate the locations on each building that can support a solar photovoltaic array. These are to be used as guidelines and do not need to be adhered to. Also reference the roof plans that will be made available via online download.